

SECTION 08330 [08 33 00]

ROLLING STEEL DOORS

Display hidden notes to specifier. (Don't know how? <u>Click Here</u>) Copyright 2013 – 2021 ARCAT, Inc All rights reserved

** NOTE TO SPECIFIER ** Wayne Dalton; Rolling steel door products.

This section is based on the products of Wayne Dalton, which is located at:

2501 S. State Highway 121 Business, Suite 200

Lewisville, TX 75067 Phone: (800) 827-3667

Web Site: www.wayne-dalton.com. [click Here] for additional information.

Wayne Dalton Rolling Doors have a long history of excellence in the design and construction of doors that have met and often exceeded the needs and expectations of even the most critical projects.

With numerous innovations created and experience acquired over the years, Wayne Dalton continues to lead all other manufacturers with both standard and custom-made doors from a variety of materials and colors to meet almost any need.

So whether it's the over-sized Model 800 rolling doors, protective FireStar rolling fire doors, or secure rolling grilles, you can feel confident that with Wayne Dalton's many years of knowledge and experience, you will get the best possible solution for your building application needs.

PART 1 GENERAL

1.1 SECTION INCLUDES

** NOTE TO SPECIFIER ** Delete items below not required for project.

- A. Rolling steel doors.
- B. Rolling steel springless high cycle doors.
- C. Rolling steel advanced performance service doors.
- D. Rolling steel fire doors.
- E. Overhead Coiling Security Shutters.

1.2 RELATED SECTIONS

** NOTE TO SPECIFIER ** Delete any sections below not relevant to this project; add others as required.

- A. Section 05500 Metal Fabrications: Support framing and framed opening.
- B. Section 06200 Finish Carpentry: Wood jamb and head trim.
- C. Section 08710 Door Hardware: Product Requirements for cylinder core and keys.
- D. Section 09900 Painting: Field applied finish.
- E. Section 16130 Raceway and Boxes: Conduit from electric circuit to door operator and from door operator to control station.
- F. Section 16150 Wiring Connections: Power to disconnect.

1.3 REFERENCES

** NOTE TO SPECIFIER ** Delete references from the list below that are not actually required by the text of the edited section.

- A. ANSI/DASMA 108 American National Standards Institute Standard Method For Testing Sectional Garage Doors And Rolling Doors: Determination Of Structural Performance Under Uniform Static Air Pressure Difference.
- B. ANSI/DASMA 203 American National Standards Institute Specifications for nonrated fire rolling doors published by Door & Access Systems Manufacturers Association International.
- C. ASTM A 123 Zinc hot-dipped galvanized] coatings on iron and steel products.
- D. ASTM A 229 Steel wire, oil-tempered for mechanical springs.
- E. ASTM A 653 Steel sheet, zinc-coated galvanized by the hot-dipped process, commercial quality.
- F. ASTM E 330 Structural performance of exterior windows, curtain walls, and doors by uniform static air pressure difference.
- G. ASTM E 413 Classification for Rating Sound Insulation

1.4 SUBMITTALS

- A. Submit under provisions of Section 01300.
- B. Product Data: Manufacturer's data sheets on each product to be used, including:
 - 1. Preparation instructions and recommendations.
 - 2. Storage and handling requirements and recommendations.
 - 3. Installation methods.
- C. Shop Drawings: Include detailed plans, elevations, details of framing members, anchoring methods, required clearances, hardware, and accessories. Include relationship with adjacent construction.

** NOTE TO SPECIFIER ** Delete the following paragraphs if LEED is not applicable.

- D. LEED Submittals: Provide documentation of how the requirements of Credit will be met:
 - List of proposed materials with recycled content. Indicate post-consumer recycled content and pre-consumer recycled content for each product having recycled content.
 - Product data and certification letter indicating percentages by weight of postconsumer and pre-consumer recycled content for products having recycled content

** NOTE TO SPECIFIER ** Delete selection samples if colors have already been selected.

- E. Selection Samples: For each finish product specified, two complete sets of color chips representing manufacturer's full range of available colors and patterns.
- F. Verification Samples: For each finish product specified, two samples, minimum size 6 inches (150 mm) long, representing actual product, color, and patterns.
- G. Manufacturer's Certificates: Certify products meet or exceed specified requirements.
- H. Closeout Submittals: Provide manufacturer's maintenance instructions that include recommendations for periodic checking, adjustment and lubrication of components.

1.5 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in performing Work of this section with a minimum of five years experience in the fabrication and installation of security closures.
- B. Installer Qualifications: Installer Qualifications: Company specializing in performing Work of this section with minimum three years and an authorized Wayne Dalton installer.
- ** NOTE TO SPECIFIER ** Include a mock-up if the project size and/or quality warrant taking such a precaution. The following is one example of how a mock-up on a large project might be specified. When deciding on the extent of the mock-up, consider all the major different types of work on the project.
 - C. Mock-Up: Provide a mock-up for evaluation of surface preparation techniques and application workmanship.
 - 1. Finish areas designated by Architect.
 - 2. Do not proceed with remaining work until workmanship, color, and sheen are approved by Architect.
 - 3. Refinish mock-up area as required to produce acceptable work.

1.6 DELIVERY, STORAGE AND HANDLING

- A. Store products in manufacturer's unopened packaging with seals and labels intact until ready for installation.
- B. Store materials off the ground in a dry, warm, ventilated weathertight location.

1.7 SEQUENCING

- A. Ensure that locating templates and other information required for installation of products of this section are furnished to affected trades in time to prevent interruption of construction progress.
- B. Ensure that products of this section are supplied to affected trades in time to prevent interruption of construction progress.

1.8 PROJECT CONDITIONS

A. Maintain environmental conditions (temperature, humidity, and ventilation) within limits recommended by manufacturer for optimum results. Do not install products under environmental conditions outside manufacturer's absolute limits.

1.9 WARRANTY

- ** NOTE TO SPECIFIER ** Include the following warranty paragraph for Model 900, 926, 800, 800C, 700, and 700C rolling service doors and Model 523 shutters not provided as a system with operators. Delete if not applicable.
 - A. Warranty: Manufacturer's limited door system warranty for 2 years for all parts and components.

PART 2 PRODUCTS

2.1 MANUFACTURERS

- A. Acceptable Manufacturer: Wayne Dalton; 2501 S. State Highway 121 Business, Suite 200, Lewisville, TX 75067. ASD. Phone: (800) 827-3667; Web Site: www.wayne-dalton.com. Email: info@wayne-dalton.com.
- ** NOTE TO SPECIFIER ** Delete one of the following two paragraphs; coordinate with requirements of Division 1 section on product options and substitutions.
 - B. Substitutions: Not permitted.
 - C. Requests for substitutions will be considered in accordance with provisions of Section 01600.
- ** NOTE TO SPECIFIER ** Select the doors required from the following paragraphs and delete those not required.

2.2 OVERHEAD COILING SECURITY SHUTTERS

- ** NOTE TO SPECIFIER ** Security Shutter Model 523 is not windload rated. This door is ideal for interior applications or exterior applications where windload is not required. Available in a maximum height of 14 feet and a maximum width of 20 feet. Contact the manufacturer for additional information.
 - A. Aluminum Security Shutter: Wayne Dalton, Model 523.
 - 1. Wall Mounting Condition:
- ** NOTE TO SPECIFIER ** Select one of the following two paragraphs and delete the one not required.
 - a. Face-of-wall mounting.
 - b. Between jambs mounting.
 - 2. Curtain: Interlocking extruded aluminum slats constructed of .05 inch aluminum. Nickel plated, steel screws and end locks to retain curtain within

guides and prevent lateral movement. Over 16 feet wide will come standard with plastic roller retainers to strengthen curtain.

3. Fenestration/Perforation:

** NOTE TO SPECIFIER ** Select one of the following paragraphs and delete those not required.

- a. Open fenestration 1 inch by 1 inch; 0.5 inch uniformly spaced openings; full curtain.
- b. Perforation full curtain.
- c. Partial open fenestration, 1 inch by 1 inch; 0.5 inch uniformly spaced openings; Height of curtain segment to be fenestrated as indicated on the Drawings.
- d. Partial perforation, height of curtain segment to be perforated as indicated on the Drawings.
- 4. Finish:

** NOTE TO SPECIFIER ** Select one of the following for powder coat and delete the ones not required. Powder coat finish is standard in the four colors listed.

- a. Powder Coat:
 - 1) Silver powder coat to match look of clear anodized aluminum.
 - 2) Bronze powder coat to match look of bronze anodized.
 - 3) White.
 - 4) Almond.
 - 5) Powdercoat color as selected by the Architect.
- Bottom Bar and Locking:

** NOTE TO SPECIFIER ** Select from the following paragraphs and delete the ones not required.

- Aluminum compact bottom bar with vinyl bulb seal with coil side left and right slide locks. Powder coat to match curtain color selection. (standard).
- b. Aluminum compact bottom bar with vinyl bulb seal with padlock-able non-coil side left and right slide locks. Powder coat to match curtain color selection.
- c. Tubular aluminum cylinder locking bottom bar with weatherstrip. Requires 1.5 inch by 3 inch wall tubes for face of wall mount.
- d. Locking doors with tube motor shall be provided with interlock micro switch.
- e. Aluminum compact bottom bar with vinyl bulb seal; non-locking.
- f. Step angle attachment option.
- 6. Guides: Extruded aluminum channels with continuous PVC wear strips. Powder coat: color to match curtain.
- 7. Brackets: Steel plate to support counterbalance, curtain and hood. Powder coat to match curtain color selection.
- 8. Hood: aluminum two-piece square hood silver powder coated to match curtain color selection. Provided with intermediate support brackets as required.
- 9. Hood with brackets; box size to match manufacturer's recommendation on housing size based on door height.
- 10. Counterbalance: Steel barrel housing counterbalance spring assembly.
- 11. Operation:

** NOTE TO SPECIFIER ** Select one of the following operation paragraphs and delete the ones not required.

- a. Manual push up.
- b. Crank operation.
- c. Electric tube motor with crank for emergency egress manual override.
- ** NOTE TO SPECIFIER ** Include the following paragraph if electric motor operation is required and delete if not required.

- 12. Electric Motor Operation: Provide UL listed electric operator, size as recommended by manufacturer:
 - a. Operator Controls:
 - b. Double throw hard wired wall switch.

PART 3 EXECUTION

3.1 EXAMINATION

- A. Do not begin installation until substrates have been properly prepared.
- B. Examine conditions of substrates, supports, and other conditions under which this work is to be performed.
- C. If substrate preparation is the responsibility of another installer, notify Architect of unsatisfactory preparation before proceeding.

3.2 PREPARATION

- A. Clean surfaces thoroughly prior to installation.
- B. Prepare surfaces using the methods recommended by the manufacturer for achieving the best result for the substrate under the project conditions.

3.3 INSTALLATION

- A. Install in accordance with manufacturer's instructions.
- B. Install door complete with necessary hardware, jamb and head mold strips, anchors, inserts, hangers, and equipment supports in accordance with final shop drawings, manufacturers instructions, and as specified herein.
- C. Fit, align and adjust rolling door assemblies level and plumb for smooth operation.
- D. Upon completion of final installation, lubricate, test and adjust doors to operate easily, free from warp, twist or distortion and fitting for entire perimeter.

3.4 ADJUSTING

- A. Test for proper operation and adjust as necessary to provide proper operation without binding or distortion.
- B. Adjust hardware and operating assemblies for smooth and noiseless operation.

3.5 CLEANING

- A. Clean curtain and components using non-abrasive materials and methods recommended by manufacturer.
- B. Remove labels and visible markings.
- C. Touch-up, repair or replace damaged products before Substantial Completion.

3.6 PROTECTION

- A. Protect installed products until completion of project.
- B. Touch-up, repair or replace damaged products before Substantial Completion.

3.7 SCHEDULES

** NOTE TO SPECIFIER ** Retain Paragraph below if required to suit project requirements. Identify products by name on the Drawings or use this paragraph to define the location of each type of material to be used. The following are some examples of schedule references. Edit as required to suit project or delete and identify products on the Drawings.

- A. : 1. 2. 3.
- B. : 1. 2. 3.

END OF SECTION